



# PARKER

C O L O R A D O

BUILDING DEPARTMENT

303-841-1970

20120 E. Mainstreet Parker, CO 80138

## Portable and Vehicle mounted Generator Checklist

- Read and follow manufacturer instructions prior to use.
- To prevent electric shock, make sure your generator is properly grounded (consult manufacturer instruction manual for grounding procedures).
- Do not over load the generator (Appliance and Equipment loads cannot be greater than the output rating of the generator)
- Use only heavy-duty outdoor rated cords for the individual Appliances or equipment with a wire gauge adequate for the load.
- Cords over all public ways (sidewalks, streets or similar areas) must be properly protected so not to create trip hazards or any physical damage to the cord itself
- Cords entire length must be free from cuts or tears and has all three pins, especially the grounding pin.
- All 125 volt, single phrase, 15-,20- and 30-ampre outlets shall have ground-fault circuit-interrupter protection for personnel
- Some vehicle-mounted generators require a separate grounding electrode when; all metal parts of the generator including the frame are not bonded together and supply equipment or receptacles are not mounded on the vehicle or generator.

**PLEASE SUBMIT COMPLETED FORM TO PARKER BUILDING DEPARTMENT**

---

Print or Type Name

---

APPLICANT SIGNATURE

---

DATE

---

PROJECT NAME -

---

PROJECT ADDRESS-

---